

**Question 1:** In volume 5, in the explanatory notes of parts “Architecture” and part “Constructions” is indicated that “part of the fence around the sport playground is destroyed and according the project it has to be restored, plastering in the areas where it is shattered and removing of the metal panels”. In the Form 4.3.2 - Bill of quantities we do not found the positions for these activities. Could you please clarify – if the renovation works of the existing fence are included in the financial offer Form 4.3.2 - Bill of quantities - which are the positions?

**Answer to question 1:** The positions for the fence are included in the financial offer and are as follows:

A	1	Fence removal	m'	387,8
---	---	---------------	----	-------

B	7	Fence		
B	7.1	New concrete boundary construction	m'	52
B	7.2	Galvanized and PVC coated chain link fence panes, 153cm height + PVC coated steal poles	m'	379

**Question 2:** In volume 5, in the technical design /part “Architecture”/ are presented:

- Drawing 02 “Situation – design solution” - according p.11 has to be implemented pavement and according p.12 – green areas;

- Drawing 06 “Open fitness” – according p.3 has to be implemented green areas.

In the presented financial offer Form 4.3.2 - Bill of quantities, p. 10 – Landscaping and sporting equipment we do not found positions for landscaping and installation of concrete plates or other flooring in the relevant areas from the above – mentioned drawings. We do not found project of part "Landscaping" as well. Could you please clarify:

– if part “Landscaping” is included in the financial offer Form 4.3.2 - Bill of quantities - which are the positions for this activity?

- if part “Landscaping” in not concluded in the financial offer Form 4.3.2 - Bill of quantities, does the positions under part “Landscaping” has to be implemented/offered as well as the pavements of the above-mentioned drawings?

**Response to question 2:** The green areas are existing even now and will not be changed. Within the project should only be formed with curbs. The same facts are shown on the drawing – Situation. The coverage remains as is the existing flooring.